



TYPE EXAMINATION CERTIFICATE

No. 22-0932

Certificate issued by Notified Body N° 1611

1. Product name: PVC FLOORING
2. Product material: PVC
3. Product type:
 - a. thickness: 4 mm - 9 mm
 - b. density: 2050 \pm 50 kg/m³
4. Numerical code of product classification:
 - a. fire behaviour: **B_fs1**
 - b. formaldehyde: **E1**
 - c. slip resistance: **DS**
5. Usage of the product: Used as interior flooring for home, hotel, school, office, hospital, shops etc.
6. Applicant: DALIAN SOPHIA NEW MATERIALS CO.,LTD
7. Address: No.168F Yingshun Road, Shuishiyong Street, Lvshun Dalian China

This certificate assures the compliance of properties of the product, which complies with the technical requirements referenced in EN 14041, EN 13501-1, EN 717-1 and EN 13893. The certificate only applies to materials that correspond to the tested sample.

The results of tests and findings on conformity of the properties of the given type with technical requirements are referenced in classification report CR 22-0932-01, Test Reports 22-0932-01, 22-0932-02, 22-0932-03 and MVZ-A-2022-002536.

Date of issuing: 25/11/2022

Valid until: November 2027

The Centre for Textile Science and Engineering of Ghent University (Belgium) is recognized as notified laboratory N° 1611 for the European regulation 305/2011 for construction products.

Didier Van Daele

Head of floorcovering/fire tests